



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TUT26769

Issued Date : 24-02-2026

Organization Type : Educational Institutions

Expiry Date : 23-02-2027

Name of the Organization : ALAGAR PUBLIC SCHOOL

Address : No.4/42/3,Muthammal Colony Extension, Thoothukudi-628002

I, A JEYARAMAN owner/manager of the ALAGAR PUBLIC SCHOOL functioning as Educational Institutions located at Sankaraperi in Thoothukudi district hereby declare that

- This Self-Declared Sanitation certificate is valid from 24-02-2026 to 23-02-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 1904 people/pupils and has 60 urinals and 77 toilets which is proportionate to the number of users as per government norms.
- 5 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00126TUT26769 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TUT26769 in the URL

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY**

Manjalneerkayal, Palayakayal- 628 152.

Phone: 04630 - 275225

E-mail: jwadtltcn@gmail.com



TC-14181

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	49499	Report Issue Date :	08/11/2025	Page No : 01 of 01
Invoice Details:	865/Dt.06/11/2025 Amt.1652/-	ULR NO.	TC-141812500000085F	

Client Name & Address Contact No / Email.ID	: Alagar Public School, 4/42/3,Muthammal Colony Extension, Thoothukudi District.				
Sample Name	:	Water			
Sample Number	:	49499			
Sample Description	:	Drinking Water – Ro Water			
Sample Submitted by	:	P.Kalaimani			
Location & Date	:	School Campus Inside & 06/11/2025			
Quantity of sample Received	:	2 Litre			
Sample Container	:	Jerry Cane			
Sample Condition on Receipt	:	Good			
Sample Received On	:	06/11/2025			
Test Commenced on	:	06/11/2025			
Test Completed on	:	08/11/2025			
Environmental Condition	:	Temperature°C	24.5 °C	Relative Humidity %	45%

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7.51	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-2023	< 5	200	600
3	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009(RA:2019)	< 5	200	600
4	Nitrate as NO ₃	mg/L	APHA 24 th Edition 2023 – 4500 – NO3 B	< 2	45	45
5	Chloride as Cl	mg/L	IS 3025-Part 32-1988(RA:2019)	< 5	250	1000
6	Fluoride as F	mg/L	APHA 24 th Edition 2023 – 4500- F-D	< 0.2	1.0	1.5
7	Sulphate as SO ₄	mg/L	IS 3025-Part 24-2022 Turbidity Method	< 5	200	400

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Acceptable Limit/Permissible Limit Drinking water specification with respect to above tested parameters. The Decision rule is not applicable.

.....End of the report.....

Revised & Authorised By
N.Raja.B.E.,
 Quality Manager,

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

Issue No./Date	01/01.10.2021	Amend. No/01 Date	01/01.06.2024	Page No	1 of 1
----------------	---------------	-------------------	---------------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Manjalneerkayal, Palayakayal Post – 628 152,

Thoothukudi.

Phone:04630 - 275225 E-mail:jwadwtlcn@gmail.com

TEST REPORT Doc.No: DWTL/FORM/7.8/01

Report No:	49500	Report Issue Date :08/11/2025
Invoice Details:	865 /Dt.06/11/2025 Amt.Rs.1652/-	

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	Appearance	Visual Observation	--	Clear	Clear	Clear
2	Odour	IS 3025 Part 5 : 1983	--	Clourless	Agreeable	Agreeable
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.0	1	5
4	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	7	500	2000
5	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	11	-	-
6	P - Alkalinity	IS 3025–Part 23-1983	mg/L	0	-	-
7	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	0	75	200
8	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	0	30	100
9	Sodium as Na	APHA 23rd Edition 2017 – 3500 Na B	mg/L	1	-	-
10	Potassium as K	APHA 23rd Edition 2017 – 3500 K B	mg/L	0	-	-
11	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
12	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
13	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0.0	0.5	0.5
14	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO ₂ B	mg/L	0	-	-
15	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0	-	-
16	Tidy's	APHA 23rd Edition 2017 – 4500 O - B	mg/L	0.00	-	-
17	Residual Chlorine as Cl ₂	APHA 23rd Edition 2017 – 4500 CL-B	mg/L	0.00	0.2	1.00

..... Report Continue

Reviewed & Authorised By,
N.Raja.B.E,
Quality Manager,

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of the test report.
4. The Result applied to the sample as Received basis



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Manjalneerkayal, Palayakayal Post – 628 152,

Thoothukudi.

Phone: 04630 - 275225 E-mail: jwadwtlcn@gmail.com

TEST REPORT Doc.No: DWTL/FORM/7.8/01

Report No:	49500	Report Issue Date :08/11/2025
Invoice Details:	865 /Dt.06/11/2025 Amt.Rs.1652/-	

Customer Name & Address Contact No / Email.ID	: Alagar Public School, 4/42/3, Muthammal Colony Extension, Thoothukudi District.				
Sample Name	:	Water			
Sample Code No.	:	49500			
Source	:	Drinking Water – Ro Water			
Sample Submitted By	:	P.Kalaimani			
Location & Date	:	School Campus Inside & 06/11/2025			
Quantity of sample Received	:	2 Litre			
Sample Container	:	Jerry Cane			
Condition Of Sample	:	Good			
Sample Received On	:	06/11/2025			
Test Commenced on	:	06/11/2025			
Test Completed on	:	08/11/2025			
Environmental Condition	:	Temperature°C	24.5 ⁰ C	Relative Humidity %	45%

The test result of sample received as follows

Sl.No	BACTERIOLOGICAL EXAMINATION:	Sample No.49500/TCN/B139 Result	BIS 10500-2012	
			Max Limit	Nil/100 ml
1	Fecal coliform CFU/100ml	Nil		

Result: The given water sample is chemically potable and bacteriologically not contaminated.

..... End of the Report


Reviewed & Authorised By,
N.Raja.B.E,
Quality Manager,

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of the test report.
4. The Result applied to the sample as Received basis